



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gslabs.com  
 Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

**REPORT OF ANALYSIS**

**REPORT # 360413121.0**

**CLIENT # TUC06**

**DATE SUBMITTED: 4/13/16**

TO: Tuckerton Board of Education  
 Elementary School  
 213 Marine Street  
 Tuckerton NJ 08087  
 ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE  
 SAMPLE ID:  
 SAMPLE LOCATION: KITCHEN HAND WASH SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:25

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.004	mg/l	0.015	4/15/16

< = less than, not detected.  
 MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
 295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

### REPORT OF ANALYSIS

Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com

REPORT # 360413122.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton

NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: CAFE HANDICAP BOY'S ROOM

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.007	mg/l	0.015	4/15/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gsllabs.com  
 Internet: www.gsllabs.com

Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

**REPORT OF ANALYSIS**

**REPORT # 360413123.0**

**CLIENT # TUC06**

**DATE SUBMITTED: 4/13/16**

TO: Tuckerton Board of Education  
 Elementary School  
 213 Marine Street  
 Tuckerton

NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: CAFE HANDICAP GIRLS' ROOM

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.005	mg/l	0.015	4/15/16

< = less than, not detected.  
 MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
 295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gsllabs.com  
 Internet: www.gsllabs.com

REPORT # 360413124.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

**REPORT OF ANALYSIS**

TO: Tuckerton Board of Education  
 Elementary School  
 213 Marine Street  
 Tuckerton NJ 08087  
 ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE  
 SAMPLE ID:  
 SAMPLE LOCATION: PRIMARY HALL WATER FOUNTAIN

DATE SAMPLED: 4/12/16 TIME SAMPLED: 05:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	

< = less than, not detected.  
 MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
 295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gslabs.com  
 Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

<b>REPORT OF ANALYSIS</b>
-------------------------------

**REPORT # 360413125.0**

**CLIENT # TUC06**

**DATE SUBMITTED: 4/13/16**

**TO:** Tuckerton Board of Education  
 Elementary School  
 213 Marine Street  
 Tuckerton  
**ATT:** Brian Mathis

**NJ 08087**

**SAMPLE TYPE:** DRINKING WATER, GRAB SAMPLE

**SAMPLE ID:**

**SAMPLE LOCATION:** ROOM #101 SINK

**DATE SAMPLED:** 4/12/16

**TIME SAMPLED:** 05:35

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.001	mg/l	0.015	4/15/16

< = less than, not detected.  
 MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
 295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

### REPORT OF ANALYSIS

Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com  
REPORT # 360413126.0

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton

NJ 08087

CLIENT # TUC06  
DATE SUBMITTED: 4/13/16

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: KITCHEN DISHWASH SINK


DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:25

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.007	mg/l	0.015	4/15/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

  
295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

**REPORT OF ANALYSIS**

REPORT # 360413127.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton  
ATT: Brian Mathis

NJ 08087

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE  
SAMPLE ID:  
SAMPLE LOCATION: KITCHEN LARGE PREP SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:25

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.008	mg/l	0.015	4/15/16

< = less than, not detected.  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
295194



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

**REPORT OF  
ANALYSIS**

Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gsllabs.com  
 Internet: www.gsllabs.com

**REPORT # 360413128.0**

**CLIENT # TUC06**

**DATE SUBMITTED: 4/13/16**

TO: Tuckerton Board of Education  
 Elementary School  
 213 Marine Street  
 Tuckerton

NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: KITCHEN SMALL PREP SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:25

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.002	mg/l	0.015	4/15/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
 295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.





# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

**REPORT OF  
ANALYSIS**

Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gslabs.com  
 Internet: www.gslabs.com

**REPORT # 360413129.0**

**CLIENT # TUC06**

**DATE SUBMITTED: 4/13/16**

**TO:** Tuckerton Board of Education  
 Elementary School  
 213 Marine Street  
 Tuckerton  
**ATT:** Brian Mathis

NJ 08087

**SAMPLE TYPE:** DRINKING WATER, GRAB SAMPLE  
**SAMPLE ID:**  
**SAMPLE LOCATION:** CAFE WATER FOUNTAIN

**DATE SAMPLED:** 4/12/16

**TIME SAMPLED:** 05:23

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.003	mg/l	0.015	4/15/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
 295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gsllabs.com  
Internet: www.gsllabs.com

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

## REPORT OF ANALYSIS

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton

REPORT # 360413130.0  
CLIENT # TUC06  
DATE SUBMITTED: 4/13/16

NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE  
SAMPLE ID:  
SAMPLE LOCATION: HALL / CAFE WATER FOUNTAIN

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.004	mg/l	0.015	4/15/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gslabs.com  
 Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

### REPORT OF ANALYSIS

**REPORT # 360413131.0**

**CLIENT # TUC06**

**DATE SUBMITTED: 4/13/16**

TO: Tuckerton Board of Education  
 Elementary School  
 213 Marine Street  
 Tuckerton NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE  
 SAMPLE ID:  
 SAMPLE LOCATION: GYM BOYS' ROOM SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:42

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.011	mg/l	0.015	4/15/16

< = less than, not detected.  
 MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*

295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gslabs.com  
 Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

## REPORT OF ANALYSIS

REPORT # 360413133.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
 Elementary School  
 213 Marine Street  
 Tuckerton

NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: GYM GIRLS' ROOM SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:40

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.011	mg/l	0.015	4/15/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*

295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

## REPORT OF ANALYSIS

REPORT # 360413134.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education

Elementary School

213 Marine Street

Tuckerton

NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: Water Fountain - Gym Hall

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:40

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.001	mg/l	0.015	4/15/16

< = less than, not detected.  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

**REPORT OF  
ANALYSIS**

REPORT # 360413135.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton

NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: ROOM 205 SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:40

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.007	mg/l	0.015	4/18/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*

295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gsllabs.com  
Internet: www.gsllabs.com

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

## REPORT OF ANALYSIS

REPORT # 360413136.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: MAIN HALL WATER FOUNTAIN

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:45

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/18/16

< = less than, not detected.  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

<b>REPORT OF ANALYSIS</b>
-------------------------------

Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gsllabs.com  
Internet: www.gsllabs.com

**REPORT # 360413137.0**

**CLIENT # TUC06**

**DATE SUBMITTED: 4/13/16**

TO: Tuckerton Board of Education

Elementary School

213 Marine Street

Tuckerton

NJ 08087

ATT: Brian Mathis

**SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE**

**SAMPLE ID:**

**SAMPLE LOCATION: GIRLS GANG BATHROOM - MAIN FLOOR**

**DATE SAMPLED: 4/12/16**

**TIME SAMPLED: 05:45**

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.008	mg/l	0.015	4/18/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.





# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gsllabs.com  
Internet: www.gsllabs.com

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

## REPORT OF ANALYSIS

REPORT # 360413138.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton

NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE  
SAMPLE ID:  
SAMPLE LOCATION: GIRLS' HANDICAP BATH - MAIN FLOOR

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:45

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.002	mg/l	0.015	4/18/16

< = less than, not detected.  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
295194



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

## REPORT OF ANALYSIS

Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com

REPORT # 360413139.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE  
SAMPLE ID:  
SAMPLE LOCATION: BOYS' HANDICAP BATH - MAIN FLOOR

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.002	mg/l	0.015	4/18/16

< = less than, not detected.  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

## REPORT OF ANALYSIS

REPORT # 360413140.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton  
ATT: Brian Mathis

NJ 08087

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: NURSE'S WORK SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.010	mg/l	0.015	4/18/16

< = less than, not detected.  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

## REPORT OF ANALYSIS

Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com

REPORT # 360413141.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton NJ 08087  
ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE  
SAMPLE ID:  
SAMPLE LOCATION: NURSE'S BATHROOM SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.003	mg/l	0.015	4/18/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



Garden State Laboratories, Inc.

Bacteriological and Chemical Testing
410 Hillside Avenue
Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT # 360413143.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education
Elementary School
213 Marine Street
Tuckerton

NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: LIBRARY SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:45

Table with 5 columns: ANALYSIS, RESULT, UNITS, MCL, DATE ANALYZED. Row 1: Lead, EPA 200.9, 0.010, mg/l, 0.015, 4/18/16.

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Handwritten signature of Harvey Klein.

295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

## REPORT OF ANALYSIS

Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com

REPORT # 360413144.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton

NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: OLD SECTION WATER FOUNTAIN - TOP FLOOR

DATE SAMPLED: 4/12/16

TIME SAMPLED: 06:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/18/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

**REPORT OF ANALYSIS**

Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gsllabs.com  
 Internet: www.gsllabs.com

**REPORT # 360413145.0**

**CLIENT # TUC06**

**DATE SUBMITTED: 4/13/16**

**TO:** Tuckerton Board of Education  
 Elementary School  
 213 Marine Street  
 Tuckerton  
**ATT:** Brian Mathis

**NJ 08087**

**SAMPLE TYPE:** DRINKING WATER, GRAB SAMPLE  
**SAMPLE ID:**  
**SAMPLE LOCATION:** ROOM 404 SINK

**DATE SAMPLED:** 4/12/16

**TIME SAMPLED:** 06:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.009	mg/l	0.015	4/18/16

< = less than, not detected.  
 MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
 295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

## REPORT OF ANALYSIS

Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com

REPORT # 360413146.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton  
ATT: Brian Mathis

NJ 08087

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:


SAMPLE LOCATION: ROOM #102 SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:35

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.004	mg/l	0.015	4/18/16

< = less than, not detected.  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

  
295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.





# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

<b>REPORT OF          ANALYSIS</b>
--

Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gslabs.com  
 Internet: www.gslabs.com

**REPORT # 360413147.0**

**CLIENT # TUC06**

**DATE SUBMITTED: 4/13/16**

**TO: Tuckerton Board of Education  
 Elementary School  
 213 Marine Street  
 Tuckerton**

**NJ 08087**

**ATT: Brian Mathis**

**SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE  
 SAMPLE ID:  
 SAMPLE LOCATION: ROOM #103 SINK**

**DATE SAMPLED: 4/12/16**

**TIME SAMPLED: 05:35**

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.002	mg/l	0.015	4/18/16

< = less than, not detected.  
 MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
 295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

## REPORT OF ANALYSIS

Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gsllabs.com  
Internet: www.gsllabs.com

REPORT # 360413148.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton  
ATT: Brian Mathis

NJ 08087

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE  
SAMPLE ID:  
SAMPLE LOCATION: ROOM #104 SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:35

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.002	mg/l	0.015	4/18/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*

295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

*Bacteriological and Chemical Testing*  
**410 Hillside Avenue**  
**Hillside, New Jersey 07205**



Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gslabs.com  
 Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

<b>REPORT OF ANALYSIS</b>
---------------------------

**REPORT # 360413149.0**

**CLIENT # TUC06**

**DATE SUBMITTED: 4/13/16**

**TO: Tuckerton Board of Education**  
**Elementary School**  
**213 Marine Street**  
**Tuckerton**

NJ 08087

**ATT: Brian Mathis**

**SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE**

**SAMPLE ID:**

**SAMPLE LOCATION: ROOM #105 SINK**

**DATE SAMPLED: 4/12/16**

**TIME SAMPLED: 05:30**

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.002	mg/l	0.015	4/18/16

< = less than, not detected.  
 MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
 295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gsllabs.com  
 Internet: www.gsllabs.com

Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

<b>REPORT OF ANALYSIS</b>
-------------------------------

REPORT # 360413150.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
 Elementary School  
 213 Marine Street  
 Tuckerton

NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: ROOM #106 SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 05:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.003	mg/l	0.015	4/18/16

< = less than, not detected.  
 MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*

295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gsllabs.com  
Internet: www.gsllabs.com

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

## REPORT OF ANALYSIS

REPORT # 360413151.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street

Tuckerton

NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: ROOM #405 SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 06:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.003	mg/l	0.015	4/18/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gsllabs.com  
Internet: www.gsllabs.com

REPORT # 360413152.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

## REPORT OF ANALYSIS

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton

NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: ROOM #406 SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 06:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.008	mg/l	0.015	4/18/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gsllabs.com  
 Internet: www.gsllabs.com

Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

**REPORT OF ANALYSIS**

**REPORT # 360413153.0**

**CLIENT # TUC06**

**DATE SUBMITTED: 4/13/16**

TO: Tuckerton Board of Education  
 Elementary School  
 213 Marine Street  
 Tuckerton  
 ATT: Brian Mathis

NJ 08087

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE  
 SAMPLE ID:  
 SAMPLE LOCATION: '90 BUILDING BOYS' ROOM

DATE SAMPLED: 4/12/16

TIME SAMPLED: 06:05

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.002	mg/l	0.015	4/18/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
 295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com

REPORT # 360413154.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

## REPORT OF ANALYSIS

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton  
ATT: Brian Mathis

NJ 08087

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE  
SAMPLE ID:  
SAMPLE LOCATION: '90 BUILDING GIRLS' ROOM

DATE SAMPLED: 4/12/16

TIME SAMPLED: 06:05

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/18/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.





# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

**REPORT OF ANALYSIS**

Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com

REPORT # 360413155.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton

NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: '90 TOP FLOOR WATER FOUNTAIN

DATE SAMPLED: 4/12/16

TIME SAMPLED: 06:05

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/18/16

< = less than, not detected.  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harry Klein*  
295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

## REPORT OF ANALYSIS

Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com  
REPORT # 360413156.0

TO: Tuckerton Board of Education  
Elementary School

213 Marine Street

Tuckerton

NJ 08087

ATT: Brian Mathis

CLIENT # TUC06  
DATE SUBMITTED: 4/13/16

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE  
SAMPLE ID:  
SAMPLE LOCATION: TEACH ROOM SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 06:10

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/18/16

< = less than, not detected.  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gsllabs.com  
Internet: www.gsllabs.com

REPORT # 360413157.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

**REPORT OF ANALYSIS**

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton

NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: TEACH ROOM BOY BATH

DATE SAMPLED: 4/12/16

TIME SAMPLED: 06:10

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.002	mg/l	0.015	4/18/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

## REPORT OF ANALYSIS

REPORT # 360413158.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton

NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: TEACH ROOM GIRL BATH

DATE SAMPLED: 4/12/16

TIME SAMPLED: 06:10

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/18/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gslabs.com  
 Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

**REPORT OF ANALYSIS**

**REPORT # 360413159.0**

**CLIENT # TUC06**  
**DATE SUBMITTED: 4/13/16**

**TO: Tuckerton Board of Education**  
**Elementary School**  
**213 Marine Street**  
**Tuckerton NJ 08087**  
**ATT: Brian Mathis**

**SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE**  
**SAMPLE ID:**  
**SAMPLE LOCATION: TEACH HALL WATER FOUNTAIN**

**DATE SAMPLED: 4/12/16**                      **TIME SAMPLED: 06:08**

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.001	mg/l	0.015	4/18/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

<b>REPORT OF ANALYSIS</b>
---------------------------

Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gsllabs.com  
 Internet: www.gsllabs.com

REPORT # 360413160.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
 Elementary School  
 213 Marine Street  
 Tuckerton NJ 08087  
 ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE  
 SAMPLE ID:  
 SAMPLE LOCATION: ART EYE WASH SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 06:08

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.002	mg/l	0.015	4/18/16

< = less than, not detected.  
 MCL = Maximum Contaminant Level allowed by State and Federal regulations.

295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gsllabs.com  
 Internet: www.gsllabs.com

Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

**REPORT OF ANALYSIS**

REPORT # 360413161.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
 Elementary School  
 213 Marine Street  
 Tuckerton NJ 08087  
 ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE  
 SAMPLE ID:  
 SAMPLE LOCATION: ART ROOM PAINT SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 06:08

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.004	mg/l	0.015	4/18/16

< = less than, not detected.  
 MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
 295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

### REPORT OF ANALYSIS

REPORT # 360413162.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: '90 BUILDING PLAYGROUND WATER FOUNTAIN

DATE SAMPLED: 4/12/16

TIME SAMPLED: 06:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/18/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.





# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gsllabs.com  
Internet: www.gsllabs.com

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

**REPORT OF  
ANALYSIS**

**REPORT # 360413163.0**

**CLIENT # TUC06**

**DATE SUBMITTED: 4/13/16**

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton  
ATT: Brian Mathis

NJ 08087

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE  
SAMPLE ID:  
SAMPLE LOCATION: ROOM 200 SINK

DATE SAMPLED: 4/12/16                      TIME SAMPLED: 06:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.001	mg/l	0.015	4/18/16

< = less than, not detected.  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

295194



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

**REPORT OF  
 ANALYSIS**

Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gsllabs.com  
 Internet: www.gsllabs.com

REPORT # 360413164.0

CLIENT # TUC06

DATE SUBMITTED: 4/13/16

TO: Tuckerton Board of Education  
 Elementary School  
 213 Marine Street  
 Tuckerton

NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: ROOM 200 BATH SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 06:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.004	mg/l	0.015	4/18/16

< = less than, not detected.  
 MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
 295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

**REPORT OF  
ANALYSIS**

**REPORT # 360413167.0**

**CLIENT # TUC06**

**DATE SUBMITTED: 4/13/16**

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton NJ 08087  
ATT: Brian Mathis

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: ROOM 204 SINK

DATE SAMPLED: 4/12/16

TIME SAMPLED: 06:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/18/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*

295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gsllabs.com  
Internet: www.gsllabs.com

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

## REPORT OF ANALYSIS

REPORT # 360428017.0

CLIENT # TUC06

DATE SUBMITTED: 4/28/16

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: BOYS' GANG BATHROOM MAIN FLOOR - TUCKERTON  
ELEMENTARY SCHOOL

DATE SAMPLED: 4/27/16

TIME SAMPLED: 05:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.003	mg/l	0.015	5/2/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
295761

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

- Retest After Sewer Line  
Repair - Water Normal USAGE



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

**REPORT OF ANALYSIS**

Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com  
REPORT # 360413142.0

TO: Tuckerton Board of Education  
Elementary School  
213 Marine Street  
Tuckerton NJ 08087  
ATT: Brian Mathis

CLIENT # TUC06  
DATE SUBMITTED: 4/13/16

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE  
SAMPLE ID:  
SAMPLE LOCATION: BOYS' GANG BATHROOM - MAIN FLOOR

DATE SAMPLED: 4/12/16 TIME SAMPLED: 05:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.181	mg/l	0.015	4/18/16

< = less than, not detected.  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

- WATER OFF GDAYS DUE  
TO Sewer Leak. BM



# Garden State Laboratories, Inc.

*Bacteriological and Chemical Testing*  
**410 Hillside Avenue**  
**Hillside, New Jersey 07205**



Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gslabs.com  
 internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

<b>REPORT OF ANALYSIS</b>
-------------------------------

**REPORT # 360428019.0**

**CLIENT # TUC06**

**DATE SUBMITTED: 4/28/16**

**TO: Tuckerton Board of Education**  
**Elementary School**  
**213 Marine Street**  
**Tuckerton**

**NJ 08087**

**ATT: Brian Mathis**

**SAMPLE TYPE: WATER, GRAB SAMPLE**

**SAMPLE ID:**

**SAMPLE LOCATION: ROOM 206 BATHROOM SINK - TUCKERTON ELEMENTARY SCHOOL**

**DATE SAMPLED: 4/27/16**

**TIME SAMPLED: 05:35**

<b>ANALYSIS</b>	<b>RESULT</b>	<b>UNITS</b>	<b>MCL</b>	<b>DATE ANALYZED</b>
Lead, EPA 200.9	0.003	mg/l	0.015	5/2/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

295761

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

**REPORT OF ANALYSIS**

Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gsllabs.com  
 Internet: www.gsllabs.com  
**REPORT # 360413132.0**

**TO:** Tuckerton Board of Education  
 Elementary School  
 213 Marine Street  
 Tuckerton

NJ 08087

**CLIENT # TUC06**  
**DATE SUBMITTED: 4/13/16**

**ATT:** Brian Mathis

**SAMPLE TYPE:** DRINKING WATER, GRAB SAMPLE  
**SAMPLE ID:**  
**SAMPLE LOCATION:** ROOM 206 SINK

**DATE SAMPLED:** 4/12/16

**TIME SAMPLED:** 05:42

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.018	mg/l	0.015	4/15/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
 295194



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gsllabs.com  
 Internet: www.gsllabs.com

Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

**REPORT OF ANALYSIS**

**REPORT # 360413166.0**

**CLIENT # TUC06**

**DATE SUBMITTED: 4/13/16**

**TO:** Tuckerton Board of Education  
 Elementary School  
 213 Marine Street  
 Tuckerton

**NJ 08087**

**ATT:** Brian Mathis

**SAMPLE TYPE:** DRINKING WATER, GRAB SAMPLE

**SAMPLE ID:**

**SAMPLE LOCATION:** ROOM 201 SINK

**DATE SAMPLED:** 4/12/16

**TIME SAMPLED:** 06:18

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.002	mg/l	0.015	4/18/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

295194

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.





# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
 410 Hillside Avenue  
 Hillside, New Jersey 07205



Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gslabs.com  
 Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director

**REPORT OF ANALYSIS**

**REPORT # 360428018.0**

**CLIENT # TUC06**

**DATE SUBMITTED: 4/28/16**

TO: Tuckerton Board of Education  
 Elementary School  
 213 Marine Street  
 Tuckerton

NJ 08087

ATT: Brian Mathis

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: ROOM 201 BATHROOM SINK - TUCKERTON ELEMENTARY SCHOOL

DATE SAMPLED: 4/27/16

TIME SAMPLED: 05:35

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.001	mg/l	0.015	5/2/16

< = less than, not detected.  
 MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
 295761

